

SERVICE RECONNECTS AND METER SET CHECKLIST

LOCATION: _____

1. SERVICE MAST:

SECURE _____ (OVERHEAD OR UNDERGROUND)

CONDITION _____ (BENT, RUSTED, CRACKED, DENTED)

2. WEATHER HEAD:

SECURE _____ (FREE OF CRACKS OR CUTTING INTO WIRES)

3. SERVICE WIRES:

SIZE AND CONDITION _____ COPPER OR ALUMINUM

4. METER SOCKET:

CONDITION _____ (BENT/DENTED/COMPLETE/WEATHER SEAL/KNOCK OUTS) NIPSCO SEAL INSTALLED _____

5. GROUNDING:

GROUND ROD _____ WATER GROUND _____ WIRE SIZE _____

BONDING _____ INSIDE WATER METER JUMPERED _____

6. SERVICE PANEL:

TYPE: BREAKERS _____ FUSES _____ SUB PANEL _____

MAIN BREAKER AMPERAGE _____ SECURE _____

MISSING COVER _____ OPEN KNOCK OUTS _____

OPEN SPACES _____ BREAKER OR FUSE RATED FOR WIRE _____

DOUBLE TAPPED CIRCUITS _____

7. OTHER UNSAFE CONDITIONS:

MISSING COVERS _____ OPEN WIRES _____

MISSING OR BROKEN FIXTURES _____ SWITCHES _____

RECEPTACLES _____

**8. ALL BREAKERS PLACED IN THE OFF POSITION AND/OR FUSES
HAVE BEEN REMOVED.**

**9. SMOKE ALARMS MUST BE IN ALL BED ROOMS, HALL WAYS,
HARD WIRES.**

APPROVED: _____

**APPROVED WITH
EXCEPTIONS:** _____

**REJECTED FOR THE FOLLOWING
REASONS:** _____

**REJECTED WITH THE REQUEST FOR A QUALIFIED, LICENSED
CONTRACTOR TO MAKE REPAIRS:** _____

INSPECTOR: _____ **DATE:** _____